



## UNISON Approved Vegetation Contractors

Company	Work type	Phone	Area	Minimum Approach Distance to Powerline (metres)		
				33,000 Volts	11,000 Volts	230/400 Volts
Unison Contracting Services Limited	Arborist	06 873 9300	Hawke's Bay	<b>0.7</b>	<b>0.6</b>	<b>0.15</b>
Unison Contracting Services Limited	Arborist	07 349 8870	Rotorua, Taupo	<b>0.7</b>	<b>0.6</b>	<b>0.15</b>
Asplundh	Arborist	06 879 9994	Hawkes Bay	<b>0.7</b>	<b>0.6</b>	<b>0.15</b>
Treescape	Arborist	0274 677 407	Rotorua, Taupo	<b>0.7</b>	<b>0.6</b>	<b>0.15</b>
Lynx Hedge & Shelter Trimming	Shelterbelt Trimmers	06 878 8811	Hawkes Bay	2.5	1.5	0.5
Greenscene Arboriculture Ltd	Arborist	06 835 3493	Hawke's Bay	2.5	1.5	0.5
Pro Arbore	Arborist, Shelterbelt Trimmers	027 550 3327	Hawke's Bay	2.5	1.5	0.5
Superior Exterior Treecare	Arborist	06 870 0779	Hawke's Bay	2.5	1.5	0.5
Brimar Trimmers Ltd	Shelterbelt Trimmers	06 844 7225	Hawkes Bay, Central HB	2.5	1.5	0.5
HB Tree Surgeons Ltd	Arborist	06 877 5275	Hawkes Bay, Central HB	2.5	1.5	0.5
Tree Line Arbor Care Ltd	Arborist	07 386 6399	Hawke's Bay, Rotorua, Taupo	2.5	1.5	0.5
PKV Treeworx Limited	Arborist	07 378 0832	Taupo	2.5	1.5	0.5

The above refers to the distance the tree / branch is away from the powerline